

TECHNICKÝ SKÚŠOBNÝ ÚSTAV PIEŠŤANY, š.p.
Certifikačný orgán certifikujúci výrobky
Product Certification Body
Krajinská cesta 2929/9, 921 01 Piešťany
Slovenská republika/Slovak Republic

CERTIFICATE

No. 0056/104/2018

Manufacturer:

Joint Stock Company "Novomet-Perm"

395, Shosse Kosmonavtov, Perm, Perm region, 614065

Russia

Product:

Permanent Magnet Motor

Type:

N319PM series N406PM series N460PM series N512PM series N744PM series and their variations

Specification:

product variations are specified on the reverse side of the certificate

This certificate confirms the compliance of the product type characteristics with the technical requirements given in standard:

EN 60034-1:2010/AC: 2010 EN 60034-5:2001/A1: 2007 EN 60034-8:2007/A1: 2014

The certificate has been issued on the basis of the tests of the product type sample. The results are recorded in the Conformity assessment report No 180500299/3 dated 14.12.2018.

Issue date:

17.12.2018

Expiry date:

16.12.2021

Issue 1

Ing. Dušan HANKO Head of Product Certification

Cf Certificati

BodyTSU Piešťany, š.p. is EU Notified Body number 1299

Specification product variations:

| N | xxx | PM | ххх | xxxxV | xxxxRPM | xxxN-M | ххх | xxx | ххх | HRZ | NDSx |
|---|-----|----|-----|-------|---------|--------|-----|-----|-----|-----|------|
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 |

Where:

1. Manufacturer: N (Novomet)

2. Series: 319, 406, 460, 512, 744

3. Permanent Magnet motor: PM

4. Power, hp (at 200Hz): 43 to 1286 (at rated rotation frequency)

Power, hp (at 150Hz): 32 to 467 (at rated rotation frequency)

Power, hp (at 120Hz): **96** to **1286** (at rated rotation frequency)

Power, hp (at 100Hz): 80 to 1072 (at rated rotation frequency)

Power, kW (at 200Hz): 32 to 465 (at rated rotation frequency)

Power, kW (at 150Hz): 24 to 349 (at rated rotation frequency)

Power, kW (at 120Hz): 72 to 960 (at rated rotation frequency)

Power, kW (at 100Hz): 60 to 800 (at rated rotation frequency)

5. Voltage, V (at 200Hz): 1010 to 4070 (at rated rotation frequency)

Voltage, V (at 150Hz): 1090 to 3100 (at rated rotation frequency)

Voltage, V (at 200Hz): 2200 to 4720 (at rated rotation frequency)

Voltage, V (at 200Hz): 1850 to 3950 (at rated rotation frequency)

- 6. Rated rotation frequency, rpm: 500 to 6000
- 7. Torque, N-m: (only for 500 and 1000 rpm in N460PM series)
- 8. Single and tandem motors: SGL -Single motor, DBL Double motor, TRP Triple motor
- 9. Corrosion resistance: CR0, CR2C, CR2S, CRM, CRMS, CR3, UCR
- 10. Heat resistance: MT, HT, UHT, HHT
- 11. Design modification: HRZ for horizontal operation, if applicable
- 12. Type of Downhole Sensor: NDS1, NDS2, NDS3, if applicable

This certificate is issued under the following conditions:

- The certificate applies to the product type and its variations specified in the above mentioned Conformity
 Assessment report
- 2. The production process/factory production control is not covered by this certificate.
- The certificate does not imply that the certification body has performed any surveillance or control of the production process.
- 4. The manufacturer shall ensure the conformity of subsequent production items with the certified type.
- Changes that may affect the conformity with the certification requirements may make the continuation of the certificate validity dependent on the evidence as for the observance of requirements under which the certificate has been awarded, or on an additional evaluation.

Oucr Certification

6. The holder of this certificate must keep the conditions specified in the General Rules for Product Certification, which are freely available at www.tsu.eu